



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-51, **Version:** 2

---

Appeal of The Home Depot At Home Services, on behalf of Famata King, to an Egress Window Non-Compliance Determination at 1922 CLEAR AVENUE.

We replaced 1 double hung window (like for like) in a twin DH configuration. Homeowner wanted new window to match.

April 19, 2012

David Nelson

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of The Home Depot At Home Services, on behalf of Famata King, to an Egress Window Non-Compliance Determination at 1922 CLEAR AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 20 inches high by 22 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.