



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-50, **Version:** 2

---

Appeal of J. D. Nelson Construction, on behalf of Steve Hanson, to an Egress Window Non-Compliance Determination at 2101 BURNS AVENUE.

Would like to keep the same size window.

May 11, 2012

DD

Appellant has appealed the same window previously, but the window dimensions were incorrect. Hearing necessary.

WHEREAS, in the matter of the Appeal of J. D. Nelson Construction, on behalf of Steve Hanson, to an Egress Window Non-Compliance Determination at 2101 BURNS AVENUE.; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the two replacement egress bedroom windows unless the contractor can provide photographs showing the windows can open to 16 inches high; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.