



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-53, **Version:** 2

Appeal of Window World to an Egress Window Non-Compliance Determination at 1029 BUSH AVENUE.

Only Egress Windows

May 8, 2012

Form completed by Molly McGrane from Window World

No hearing necessary.

Yes, 2 inches egress opening height. Variance based on window specs attached to appeal.

WHEREAS, in the matter of the Appeal of Window World to an Egress Window Non-Compliance Determination at 1029 BUSH AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of one slider replacement egress bedroom window measuring 22.81 inches high by 22.06 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.