



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-218, **Version:** 2

Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 443 BANFIL STREET.

Request variance of window due to size.

May 25, 2012

Michael Efferson

No hearing necessary.

Yes, 5 inches egress opening height for all sleeping rooms.

WHEREAS, in the matter of the Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 443 BANFIL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress bedroom windows in both units; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.