



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-216, **Version:** 2

Appeal of Jacob Devney to a Fire Inspection Correction Notice at 912 FREMONT AVENUE.

Windows in the bedroom (dimensions listed). Would like a variance so that these original windows can be approved in use by a rental property.

May 14, 2012

Mike Cassidy

No hearing necessary.

Yes, 1 inch egress opening height.

WHEREAS, in the matter of the Appeal of Jacob Devney to a Fire Certificate of Occupancy Correction Notice at 912 FREMONT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress windows in the first and second floor bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.