Legislation Text

File #: RLH WP 12-54, **Version:** 2

Appeal of Jeff Beissel, Beissel Window and Siding Company, to an Egress Window Non-Compliance Determination at 2184 LARRY HO DRIVE.

Bedroom egress

May 11, 2012

R, Rehn

No hearing necessary.

Yes, 8 inches egress opening height.

WHEREAS, in the matter of the Appeal of Jeff Beissel, Beissel Window and Siding Company, to an Egress Window Non-Compliance Determination at 2184 LARRY HO DRIVE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a 8-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 16-5/8 inches high by 31-3/8 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.