



Legislation Text

File #: RLH FOW 12-214, **Version:** 2

Appeal of Lori Brown to a Fire Certificate of Occupancy Correction Notice at 1038 STINSON STREET.

Windows

May 16, 2012

Sebastian Migdal

No hearing necessary.

Yes, lower level -bedroom 1 - 4 inches egress opening height; lower level bedroom 2 - 5 inches egress opening height; lower level bedroom 3 - 5 inches egress opening height; upper level bedrooms 1 and 2 - 5 inches egress opening height; and upper level bedroom 3 - 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Lori Brown to a Fire Certificate of Occupancy Correction Notice at 1038 STINSON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in the lower level bedroom one and upper level, bedroom three; and grant a 5-inch variance on the openable height of the egress windows in the the lower level bedroom two, bedroom three, upper level bedroom one and upper level bedroom two; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.