



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-205, **Version:** 2

---

Appeal of Debbie Vasquez, on behalf of Real Property Management, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 441 VIEW STREET.

Windows

February 28, 2012

Sean Westenhofer

Hearing necessary.

WHEREAS, in the matter of the Appeal of Debbie Vasquez, on behalf of Real Property Management, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 441 VIEW STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of the egress window in the east bedroom of Unit 2 and grant an 8-inch variance on the openable height of the egress window in the south bedroom of Unit 1; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.