



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-207, **Version:** 2

Appeal of Raymond Wyatt to a Fire Inspection Correction Notice at 876 WHEELLOCK PARKWAY EAST.

See appeal

April 25, 2012

Benjamin Ellis

No hearing necessary.

Yes, 6 inches egress opening height. If standard size step is installed and permanently affixed to the wall for the full width of the window, 5 inch variance on minimum sill height.

WHEREAS, in the matter of the Appeal of Raymond Wyatt to a Fire Inspection Correction Notice at 876 WHEELLOCK PARKWAY EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress window in the first floor bedroom, and grant a variance on the sill height on the condition that the bed is being used as a step; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.