



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-242, **Version:** 2

Appeal of Hong Yang to a Fire Inspection Correction Notice (windows only) at 645 GOTZIAN STREET.

Deficiency #1 - Window in the west bedroom on the 2nd floor measured H 21.5in, W 27 in., glazed area H 49 in. W 23.5 in.

The code requirement for the window is H 24 in.

May 10, 2012

Mike Cassidy

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Hong Yang to a Fire Inspection Correction Notice at 645 GOTZIAN STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the second floor west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.