



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-233, **Version:** 2

Appeal of Shirley and Jay Olson to a Fire Inspection Correction Notice (windows only) at 487 DESNOYER AVENUE.

The home was bought by my father in 1959. the windows in the split level home lower bedroom size are 31" wide and 21" high.

May 10, 2012

Jay Bohan

No hearing necessary.

Yes, 3 inch egress opening height.

WHEREAS, in the matter of the Appeal of Shirley and Jay Olson to a Fire Inspection Correction Notice (windows only) at 487 DESNOYER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the first floor bedrooms of Unit 487 and 493; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.