



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-71, **Version:** 2

Appeal of Daniel Schmidt, Saint Paul-Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 691 VIRGINIA STREET.

(Windows)

June 14, 2012

Unknown

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Public Health, to an Egress Window Non-Compliance Determination at 691 VIRGINIA STREET; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 20.06 inches high by 23.9 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.