



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 13-168, **Version:** 2

Appeal of Michael and Stephanie Huber to a Correction Notice-Fostercare Inspection at 1697 HUBBARD AVENUE.

Bedroom egress windows

July 12, 2013

James Perucca

No hearing necessary.

Yes, 7 inches on egress opening height for listed windows.

WHEREAS, in the matter of the Appeal of Michael and Stephanie Huber to a Correction Notice-Fostercare Inspection at 1697 HUBBARD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the main floor northeast and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.