



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 13-13, **Version:** 2

Appeal of Gary Binns to a Correction Notice - Foster Care Inspection at 703 FULLER AVENUE.

Inspection from fire inspector. We are appealing the upper bedroom windows. The windows are 22" x 28" wide and there are two of them. Home was built in 1955 regular windows.

September 20, 2013

James Perucca

No hearing necessary.

Yes, 2 inches egress opening height for upper level bedroom.

WHEREAS, in the matter of Appeal of Gary Binns to a Correction Notice - Foster Care Inspection at 703 FULLER AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in the upper level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.