



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 13-244, **Version:** 2

---

Appeal of Robert Johnson to a Fire Inspection Correction Notice at 276 EXCHANGE STREET SOUTH.

Sprinkler in 2nd floor closet.

October 24, 2013

Kris Show-Fiske

WHEREAS, in the matter of Appeal of Robert Johnson to a Fire Inspection Correction Notice at 276 EXCHANGE STREET SOUTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal provided that no combustible materials are stored in the un-sprinkled closets; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.