



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-80, **Version:** 2

Appeal of Brian Nilles, Contractor; on behalf of Mary Jo Connelly; to an Egress Window Non-Compliance Determination at 1028 FIFTH STREET EAST.

(2 Windows)

June 27, 2012

J Hoffman

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Brian Nilles, Contractor; on behalf of Mary Jo Connelly; to an Egress Window Non-Compliance Determination at 1028 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 21 inches high by 23.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.