



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-262, **Version:** 2

Appeal of Robert Torning to a Fire Inspection Correction Notice at 996 BURGESS STREET.

#3 - Unit 1 rear bedroom. Window is certainly large enough for a person to escape. Windows are nice newer vinyl - large and open easily

June 11, 2012

Sebastian Migdal

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Robert Torning to a Fire Inspection Correction Notice at 996 BURGESS STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5 inch variance on the openable height of the window in the rear bedroom, Unit 1; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.