



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-277, **Version:** 2

Appeal of Tarryl Olson to a Fire Inspection Correction Notice at 1627 FOURTH STREET EAST.

We are asking for a variance on the 2 main floor bedroom windows.
The casement window has been ordered & will be installed by 7/5/12.

June 21, 2012

Sean Westenhofer

No hearing necessary.

Yes, 4 inches egress opening height for all listed windows; except 2nd floor north, which is a 2 inches egress opening width variance.

WHEREAS, in the matter of the Appeal of Tarryl Olson to a Fire Inspection Correction Notice at 1627 Fourth Street East, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress main floor southeast bedroom east window, main floor northeast bedroom east window, main floor northeast bedroom north window, and second floor north casement window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.