



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-265, **Version:** 2

Appeal of Ying Chu-Yang-Heu to a Fire Certificate of Occupancy Inspection Correction Notice at 761 CASE AVENUE.

(Item 7, escape window)

June 5, 2012

Mike Cassidy

No hearing necessary.

Yes, 6 inches egress opening height.

WHEREAS, in the matter of the Appeal of Ying Chu-Yang-Heu to a Fire Certificate of Occupancy Inspection Correction Notice at 761 CASE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress windows in the 2nd floor, northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.