

## City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

## **Legislation Text**

File #: RLH FOW 14-3, Version: 2

Appeal of Elizabeth A. Gardner to a Correction Notice-Foster Care Inspection at 1485 HOLTON STREET.

My fire inspection was conducted in order for me to submit an application to be a foster parent for Ramsey County. The five windows in the bedroom on the second floor do not open up to the dimensions required in code because my home was built prior to when this code was written... (See application for further details on purpose of appeal)

February 7, 2014

James Perucca

No hearing necessary.

Yes, for master bedroom 6 inches egress opening height and for southside bedroom 3 inches in opening height.

WHEREAS, in the matter of the Appeal of Elizabeth A. Gardner to a Correction Notice-Foster Care Inspection at 1485 HOLTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress windows in the master bedroom and grant a 3-inch variance on the openable height of the egress window in the southside bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.