



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 15-9, **Version:** 2

Appeal of Charles Nosie to a Fire Inspection Correction Notice at 1126 FOURTH STREET EAST.

WHEREAS, in the matter of Appeal of Charles Nosie to a Fire Inspection Correction Notice at 1126 FOURTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal if the ceiling height can be increased to 6 feet 9 inches for at least one-third of the room's square footage; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.