



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 15-257, **Version:** 2

Appeal of Bill Huepenbecker, on behalf of RiverCentre, to a Fire Inspection Correction Notice at 150 KELLOGG BOULEVARD WEST.

WHEREAS, in the matter of the Appeal of Bill Huepenbecker, on behalf of RiverCentre, to a Fire Inspection Correction Notice at 150 KELLOGG BOULEVARD WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the southeast stairwell with the following conditions: standpipe relocate to the south side of the ramp, labeled; exit signs removed; stairwell continued to be blocked and maintained structurally sound; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.