



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 17-6, **Version:** 2

---

Appeal of Lon LeVitre for ResCare MN to a Correction Notice - DHS Licensing Inspection at 1585 RICE STREET.

### **AMENDED 4/19/17**

WHEREAS, in the matter of the Appeal of Lon LeVitre for ResCare MN to a Correction Notice - DHS Licensing Inspection at 1585 RICE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council 1) grant to July 1, 2017 for the interior guardrails to come into compliance; 2) forthcoming denial on the fire rated corridor doors entering the area on the second floor laundry and first floor training kitchen allowing to July 1, 2017 for compliance; 3) granting the appeal on the fire rated corridor doors on the condition that there be no hot plates, toaster ovens or open flames in shared living spaces; and 4) recommending the installation of 20 minute fire doors for the resident bedrooms adjacent to the laundry and training kitchen areas; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.