



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 18-26, **Version:** 2

Appeal of Heidi Schwarze, Unilev Management Corp o/b/o Bureau of Alcohol, Tobacco and Firearms, to a Fire Inspection Correction Notice at 30 SEVENTH STREET EAST.

WHEREAS, in the matter of the Appeal of Heidi Schwarze, Unilev Management Corp o/b/o Bureau of Alcohol, Tobacco and Firearms to a Fire Inspection Correction Notice, at 30 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal if the 3 conditions listed below pertaining to the interview room are in compliance by April 9:

- 1) quick response sprinklers;
- 2) automatic door lock release in the event of alarm condition;
- 3) automatic smoke detectors within room tied to alarm system; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.