



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 23-29, **Version:** 2

---

Appeal of Albert Schuna to a Correction Order at 1344 SCHLETTI STREET.

WHEREAS, in the matter of appeal of Albert Schuna to a Correction Order at 1344 Schletti Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on condition that the requirements of the 1995 permit continue to be met: 1) no combustible/flammable liquids or gasses will be allowed in garage at any time; 2) no combustible/flammable liquid or gas-powered equipment will be allowed in garage at any time; and 3) owner shall provide (minimum) a 2A-10BC Fire Extinguisher; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.