



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-106, **Version:** 1

Appeal of Ronald Gnetz to a Certificate of Occupancy Deficiency List for property at 2048 Bohland Avenue (Ward 3)

2048 Bohland Avenue

Egress Windows.

August 19, 2010

September 7, 2010

Granted without hearing.

Grant a 1.5-inch variance on the openable height of the bedroom egress window in Unit 1; grant a 4-inch variance on the openable height of the egress window in the south bedroom of Unit 4; grant a 5.5- inch variance on the openable height of the egress window in the north bedroom of Unit 4.

[Enter the target date for this item to be introduced to Council]