

Legislation Text

File #: ALH 10-107, Version: 1

Appeal of Eastern Heights Lutheran Church to a Certificate of Occupancy Deficiency List for property at <u>2127</u> <u>Margaret Street</u> (Ward 7)

2127 Margaret Street

Parsonage located at 2127 Margaret St. Appealing egress windows in an existing structure.

June 17, 2010

September 7, 2010

Granted without hearing.

Grant a 4.5-inch variance on the openable height of the egress windows in the main floor southeast, northwest and southwest bedrooms. Grant a 3.5-inch variance on the openable height of the egress window in the basement bedroom.

[Enter the target date for this item to be introduced to Council]