



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 10-108, **Version:** 1

---

Appeal of Eric Guida to a Certificate of Occupancy Deficiency List for property at 1194 Sixth Street East (Ward 7)

1194 Sixth Street East

#1 egress windows in lower unit bedrooms, & #9 re egress window in upper unit bedroom. [Note from staff: Now appealing Item 3 on the August 12, 2010 Deficiency List. He is going to talk to the inspector and call me on Monday.]

July 12, 2010

September 7, 2010

Grant without hearing.

Grant a 2-inch variance on the openable height of the Lower Unit bedroom egress windows; grant a 4-inch variance on the openable height of the Unit 2 bedroom egress windows.

[Enter the target date for this item to be introduced to Council]