



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-305, **Version:** 1

Appeal of Ramsey County Public Health on behalf of Ruby Fair to an Egress Window Non-Compliance Determination at 726 Cook Avenue East.

726 Cook Avenue East

Egress windows.

October 22, 2010

No hearing necessary, as only windows under appeal.

Grant variance of 2" in openable height for double hung window with egress opening of 19.2" width and 22" height

Grant variance of 4" in openable height and 1" in openable width for windows with egress opening of 19.3" width and 20" height