



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-309, **Version:** 1

Appeal of 33rd Company, Inc. to a Fire Certificate of Occupancy Correction Order at 65 Battle Creek Road.

65 Battle Creek Road

Egress windows.

October 15, 2010

No hearing necessary, as only windows under appeal.

Basement northeast bedroom and main floor master bedroom: Grant variance of 3" in openable width.

Basement second window: Grant variance of 7.5" in openable height.