



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 10-433, **Version:** 1

---

Appeal of Progressive Construction Homebuilding on behalf of Bob and Lynn Connolly to an Egress Window Non-Compliance Determination at 105 ROSE AVENUE WEST.

Egress windows: size, change dimensions, length, and height. I have the size I need, but I have 28 width and 20 7/8 height. If we reverse the height and width, it will pass.

November 15, 2010

No hearing necessary, recommend variance.