

Legislation Text

File #: ALH 10-531, Version: 1

Appeal of Steve Sauro to a Fire Certificate of Occupancy Approval with Corrections at 49 LAWSON AVENUE WEST.

Correction would take structural work at considerable cost. Width of window is 3" over requirements. Height of window 2 1/2" short.

November 24, 2010

No hearing Necessary. Recommend grant of a variance.