



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 11-326, **Version:** 1

Appeal of Nick Hendrikson to a Fire Inspection Correction Notice at 415 CRETIN AVENUE SOUTH.

Requesting variance on windows. Still meets the minimum 5 square feet glazed area.

February 10, 2011

No Hearing Necessary. Recommend variance for egress window dimensions.