



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 11-330, **Version:** 1

Appeal of Michael McMahon to a Fire Inspection Correction Notice at 1661 Hubbard Avenue.

Windows are 7.0 sq ft of glazed area per inspector. Windows upgraded with vinyl windows in past 10 years. 17.5 high & 23.5. There is also a full exit door on 2nd floor. Bungalow style with windows in the dormer.

February 11, 2011

No hearing Necessary. Recommend variance on egress window dimensions.