



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-47, **Version:** 2

Appeal of Laura Hay to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1979 IVY AVENUE EAST.

Egress windows

March 21, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Laura Hay to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1979 IVY AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress bedroom window; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.