



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-14, **Version:** 2

Appeal of Joe McKasy to a Fire Inspection Correction Notice at 660 BURLINGTON ROAD.

Windows are 18 X 36 (20 x 36, not 20 x 24)

April 7, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Joe McKasy to a Fire Inspection Correction Notice at 660 BURLINGTON ROAD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of the egress windows in the upper floor northwest, northeast, and southeast bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.