



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-14, **Version:** 2

Appeal of Daniel Schmidt and Jim Yannarely, Saint Paul Ramsey County Department of Public Health, on behalf of Tammie Neuenfelt, to an Egress Window Non-Compliance Determination at 658 CHARLES AVENUE.

Egress window

April 25, 2011

Yes, 5" in the height of the egress opening. No hearing necessary.

WHEREAS, in the matter of the appeal of Daniel Schmidt and Jim Yannarely, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 658 CHARLES AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the Saint Paul City Council grant a 5 inch variance in the opening height of the egress window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.