



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-18, **Version:** 2

Appeal of Rita Tierney, 33rd Company, to a Fire Inspection Correction Notice at 2116 SCHEFFER AVENUE.

Applying for variance for 2nd floor windows. The window sizes are as follows:

East - 18.25 h X 38 w, glazed 8.6 sq. ft.

West - 18.5 h X 38 w, glazed 8.6 sq. ft.

(See attached inspection report)

April 5, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Rita Tierney, 33rd Company, to a Fire Inspection Correction Notice at 2116 SCHEFFER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5.7-inch variance on the openable height of the egress windows in the second floor east and west bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.