



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-17, **Version:** 2

Appeal of Renewal by Andersen, on behalf of Annette and Kirby Hansen, to an Egress Window Non-Compliance Determination at 2221 EDGCUMBE ROAD.

We are appealing the replacement of 3 windows that will not comply w/egress policy. Current dimensions allow for 12-1/8" clear opening width. Clear opening height is exceeded by 10-22" for each window. Current windows are less than 5" sill to grade. Excess in openable height and overall glazed area for each window.

April 25, 2011

Deny the appeal

WHEREAS, in the matter of the appeal of Renewal by Andersen, on behalf of Annette and Kirby Hansen, to an Egress Window Non-Compliance Determination at 2221 EDGCUMBE ROAD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; And

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal for an 8 inch variance in the egress window opening width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.