



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-24, **Version:** 2

---

Appeal of Daniel Schmidt and Jim Yannarely, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 1147 MATILDA AVENUE.

(3 windows)

May 20 2011

Yes, 2-inch variance in the opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Daniel Schmidt and Jim Yannarely, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 1147 MATILDA AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 22 inches high by 25 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.