



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-75, **Version:** 2

Appeal of Matt Schumacher to a Fire Certificate of Occupancy Correction Notice at 1088 SUMMIT AVENUE.

Only Egress Windows (see attachment)

June 8, 2011

Yes, 2 inches in egress opening height.

No hearing necessary.

WHEREAS, in the matter of the appeal of Matt Schumacher to a Fire Certificate of Occupancy Correction Notice at 1088 SUMMIT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress windows in both units - 3 bedrooms in each unit; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.