



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-30, **Version:** 2

---

Appeal of Renewal by Andersen, on behalf of Roger Krenner, to an Egress Window Non-Compliance Determination at 1061 PLEASANT AVENUE.

We are appealing 6 replacement windows that will not comply w/St. Paul egress policy. The current windows are short by no more than 6" in height and are compliant w/minimal allowed width. Please approve.

May 31, 2011

Yes, 2 inches in the egress height requirement. No hearing necessary.

WHEREAS, in the matter of the appeal of Renewal by Andersen, on behalf of Roger Krenner, to an Egress Window Non-Compliance Determination at 1061 PLEASANT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.