



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-83, **Version:** 2

Appeal of Christopher Chiabotti to a Fire Certificate of Occupancy Inspection Correction Notice at 1039 EARL STREET.

Windows installed, permitted, inspected, and approved in 2005.

June 8, 2011

Yes, 2 inches in the openable height of the egress window opening.

No hearing necessary.

WHEREAS, in the matter of the appeal of Christopher Chiabotti to a Fire Certificate of Occupancy Inspection Correction Notice at 1039 EARL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends granting a 2-inch variance on the openable height of the egress windows in both bedrooms, Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.