



Legislation Text

File #: RLH WP 11-32, **Version:** 2

Appeal of Window World, on behalf of Hanz Lehrke, to an Egress Window Non-Compliance Determination at 1871 STILLWATER AVENUE.

Asking for variance on windows

June 16, 2011

Yes, 6.6 inches in the egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Window World, on behalf of Hanz Lehrke, to an Egress Window Non-Compliance Determination at 1871 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends granting a 6.5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 17.5 inches high by 25.5 inches wide, Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.