



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-74, **Version:** 2

Appeal of Youa Xiong to a Revocation of Fire Certificate of Occupancy and Order to Vacate at 928 EDMUND AVENUE. (Window Appeal Only)

Windows on second floor bedrooms to maintain an approved escape window from each sleeping room.

June 13, 2011

Yes, 6 inch variance in egress opening height.

No hearing necessary.

WHEREAS, in the matter of the appeal of Youa Xiong to a Revocation of Fire Certificate of Occupancy and Order to Vacate at 928 EDMUND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress window in the 2nd floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.