



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-31, **Version:** 2

---

Appeal of Grant Remodeling, on behalf of Danalex Partners, to an Egress Window Non-Compliance Determination at 1896 GRAND AVENUE.

Only Egress Windows

June 14, 2011

Yes, 1 inch in opening width.

WHEREAS, in the matter of the appeal of Grant Remodeling, on behalf of Danalex Partners, to an Egress Window Non-Compliance Determination at 1896 GRAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of two slider replacement egress bedroom windows measuring 40 inches high by 19 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.