



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-85, **Version:** 2

Appeal of Brook Biggers to a Fire Certificate of Occupancy Inspection Correction Notice at 1137 HYACINTH AVENUE EAST.

22" window in small bedroom

Please note that we live in Colorado now with job transfer and to come for a hearing would be very difficult.

June 7, 2011

Yes, 2 inches in the egress window opening height.

No hearing necessary.

WHEREAS, in the matter of the appeal of Brook Biggers to a Fire Certificate of Occupancy Inspection Correction Notice at 1137 HYACINTH AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the second floor east bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.