



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-84, **Version:** 2

Appeal of Randy J. Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 866 ARKWRIGHT STREET.

Windows seem to work fine and a person could get out in case of emergency if opened properly.

May 11, 2011

Yes, 2 inches in openable height of egress window in downstairs east bedroom; 6 inches in openable height of egress window in downstairs west bedroom.

No hearing necessary.

WHEREAS, in the matter of Appeal of Randy J. Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 866 ARKWRIGHT STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the downstairs east bedroom and a 6-inch variance on the openable height of the egress window in the downstairs west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.