



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-40, **Version:** 2

Appeal of Bryan Horton, Renewal by Andersen, on behalf of Eva Smith, to an Egress Window Non-Compliance Determination at 1830 MECHANIC AVENUE.

We are appealing 7 replacement windows that will not comply w/egress policy. Window openings will be short in height by 6". Opening width and overall glazed area will be exceeded. Please approve.

June 24, 2011

Yes, 6 inches in the opening height of the egress opening.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Eva Smith, to an Egress Window Non-Compliance Determination at 1830 MECHANIC AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of seven double hung replacement egress bedroom windows measuring 18 inches high by 36 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.