



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH CO 11-8, **Version:** 2

Appeal of Heather Matias, on behalf of Selby-Dale Cooperative, to a Correction Notice-Complaint Inspection at 666 DAYTON AVENUE.

Windows - Asking for a variance on windows in bedrooms. They are only 1-1/2" off required.

May 19, 2011

Yes, 2 inches in the opening height of the egress window in the 4 sleeping rooms listed in this set of Fire Inspection Orders.

No hearing necessary.

WHEREAS, in the matter of the appeal of Heather Matias, on behalf of Selby-Dale Cooperative, to a Correction Notice-Complaint Inspection at 666 DAYTON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all four sleeping rooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.